



Institut Français du
Textile et de l'Habillement

This document is the translation of the French
certificate n° 21-02823 L on September 21th 2021,
delivered by IFTH.

MATERIAL REACTION TO FIRE CLASSIFICATION
REPORT PREPARED IN COMPLIANCE WITH AMENDED 5 OF THE FRENCH HOME OFFICE
REGULATION DATED NOVEMBER 21ST, 2002 (OFFICIAL GAZETTE DATED DECEMBER 31, 2002)

Valid five years from issue date

CERTIFICATE N° 21-02823 L

And appendices of 5 pages

MATERIAL presented by:

SENFA
1 RUE DE MORAT
BP 8
67601 SELESTAT CEDEX
FRANCE

TRADE NAME:

SENFA - THEATER BLACK BACK

BRIEF DESCRIPTION:

Polyester fabric with flame retardant acrylic on one side.
Measured surface weight: 205 ± 15 g/m²
Measured thickness: $0,15 \pm 0.02$ mm
Colours: One black side and one white

TEST REPORT:

N° 21-02823 E1-V1 on September 21th 2021

TESTS:

Electrical burner test
Flame persistence test

CLASSIFICATION:

M 1

CLASSIFICATION DURATION (article 5 of appendix 2) : unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law dated March 14, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on September 21th 2021

Lucile MULTARI
Engineer Tests and Trials